

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 27.03.2025

It is certified that an inspection team headed by Ashutosh Sharma

(Name of Officers with designation) from Sanitary Inspector PHED MC Parwanoo

inspected the Anand School, opp bank square, sector-1, Parwanoo

(Name & Address of the school) on .....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. TRO/EN-2503271610 dated 27.03.2025

of ..... (PHED Lab) certified that the

Anand School ( Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till .....

Signature with Seal: Sanitary Inspector  
Name : Municipal Council  
Designation : Parwanoo (H.P.)  
Name & Address of the Office / Department : .....

To Anand School  
Opp. Bank Square, Sec.-1, Parwanoo  
(Name & Address of the Institution)

ANAND SCHOOL  
(A UNIT OF DCAET)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



## TEST REPORT

Report No. : TR01EN-2503271610

ULR No. : TC1489625000007981F

### Issued To :

**Anand School ( A unit of Deep C Anand Education Trust)**

Sector-1, Parwanoo  
Parwanoo, 173220  
Himachal Pradesh, India

Sample Registration No. : SR01EN-2503200921  
Sample Name : Water Sample (Potable Water)  
Sample Condition : Good

Received On : 20-03-2025  
Commenced On : 20-03-2025  
Completed On : 26-03-2025  
Date of Report : 27-03-2025

### Sample Details (if any)

Sample Quantity : 2 Ltr  
Packaging Mode : Packed in can  
Batch No./QR Code : NA  
Date of Manufacture : NA  
Sample Submission Type : Submitted  
Customer Reference : TRF/18/03/2025  
Any Other Information : NA  
Test Report as per : IS 10500:2012

Grade : NA  
Date of Expiry : NA

With Amendment No.(s) : 01 to 04

Description: Clear Colourless Liquid							
S. No.	Parameter	Measuring Unit	Instrument	Method	Result	Acceptable Limit	Permissible Limit
<b>Discipline : Chemical</b>							
<b>Group : Water</b>							
<b>(I) Organoleptic &amp; Physical Parameter</b>							
1	Colour (True Colour)	Hazen	Visual Examination	IS 3025 (Part 4) : 2021	2	5 Max.	15 Max.
2	Odour	NA	Organoleptic	IS: 3025 (P-5)-2018	Agreeable	Agreeable	Agreeable
3	pH Value	NA	pH Meter	IS: 3025 (Part-11): 2022	7.38	6.5-8.5	No relaxation
4	Taste	NA	Organoleptic	IS 3025(Part-8): 2023	Agreeable	Agreeable	Agreeable
5	Total Dissolved Solids	mg/l	Gravimetric	IS: 3025 (P-16): 2023	194	500 Max.	2000 Max.
6	Turbidity	NTU	Turbidity Meter	IS 3025(Part-10): 2023	<0.5	1 Max.	5 Max.
<b>(II) Parameters Concerning Undesirable Substances in excess amount</b>							
1	Chloride(as Cl)	mg/l	Titration	IS: 3025 (P-32)-1988 (RA2019)	9	250 Max.	1000 Max.
2	Fluoride(as F)	mg/l	Visual Examination	IS: 3025 (P-60)-2008 (RA 2019)	BLQ(LOQ:0.1)	1.0 Max.	1.5 Max.

**Authorized Signatory(Microbiology)**

Name : Deepika Heera

Discipline : Biological

Date : 27/03/2025

**Authorised by**

Name : Vikrant Saini

Discipline : Chemical

Date : 27/03/2025

### Disclaimer :

- The test result related only to the items tested.
- The test report shall not be reproduced in full or part without the written approval of ITC Labs, Chennai.
- The test items shall not be retained more than 15 days from the date of issue of test report except in the case as required by the regulatory bodies and Customers.



## TEST REPORT

Report No. : TR01EN-2503271610

ULR No. : TC1489625000007981F

3	Free Residual Chlorine	mg/l	Titration	IS: 3025 (P-26): 2021	Not Applicable	0.2 Min.	1.0 Max.
4	Iron(as Fe)	mg/l	ICPMS	IS 3025 (Part 65) : 2022	0.049	1.0 Max.	No relaxation
5	Total Hardness(as CaCO <sub>3</sub> )	mg/l	Titration	IS: 3025 (Part 21)-2009 (RA 2019)	123	200 Max.	600 Max.
<b>Discipline : Biological</b>							
<b>Group : Water</b>							
<b>(III) Microbiological Tests</b>							
1	<i>E.coli</i>	Per 100ml	Microbiological	IS 15185: 2016	Absent/100ml	Shall not be detectable in any 100 ml sample	No Relaxation
2	<i>Total Coliform</i>	Per 100ml	Microbiological	IS 15185: 2016	Absent/100ml	Shall not be detectable in any 100 ml sample	No Relaxation

**NOTE** : NA- Not Applicable, LOQ- Limit of Quantification, BLQ- Below limit of Quantification. Sample Submitted by Customer

**REMARKS** : The above sample complies to IS 10500 : 2012 drinking water specification with respect to the above tested Parameters

\*\*\*\*\*End of Report\*\*\*\*\*




Authorized Signatory(Microbiology)

Name : Deepika Heera

Discipline : Biological

Date : 27/03/2025



Authorised by

Name : Vikrant Saini

Discipline : Chemical

Date : 27/03/2025

Disclaimer :

- The test result related only to the items tested.
- The test report shall not be reproduced in full or part without the written approval of ITC Labs, Chennai.
- The test items shall not be retained more than 15 days from the date of issue of test report except in the case as required by the regulatory bodies and Customers.